

ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

Central Electricity Board

CORPORATE OFFICE

P.O. BOX 134 | Rue du Savoir | Cybercity, Ebène 72201

MAURITIUS

TEL No. : (230) 404 2000
TELEFAX No. : (230) 454 7630 / 7632
E-MAIL : ceb@intnet.mu
WEBSITE : ceb.mu
VAT Reg. No. : VAT22000591
BRN : F07000041

OUR REF: **CPB/30/2023 – Add. 5**

YOUR REF:

12 January 2024

Attention: All Bidders

Dear Sir/Madam,

CPB/30/2023 - Design, Supply, Installation, Testing and Commissioning of Ten 66/22 kV GIS Substations for the Republic of Mauritius

Addendum No. 5

Bidders are hereby informed that the following Clauses in the Bid Document are amended as follows:

1. Bidders are hereby informed that Section 14.3.14 132/66 kV Switchgear is amended as follows:

Original Text	Amended Text
<p>Special Tools and Test Equipment</p> <ul style="list-style-type: none">• Equipment for recovery, storage, filtering, and refilling of SF6 gas shall be provided. It would be acceptable for one set of this equipment to be provided to cover all seven sites. Training to be provided.	<p>Special Tools and Test Equipment</p> <ul style="list-style-type: none">• Equipment for recovery, storage, filtering, and refilling of SF6 gas shall be provided. It would be acceptable for one set of this equipment to be provided to cover all ten sites. Training to be provided.


2. Bidders are hereby informed that Section 17.2.6 Metallic Screen is amended as follows:

Original Text	Amended Text
<p>Metallic Screen</p> <p>The cable shall be provided with a continuous metallic screen composed of helically applied plain annealed copper wire which shall be rated to carry the phase to earth short circuit fault current specified in Section 1.3 of this specification.</p>	<p>Metallic Screen</p> <p>The cable shall be provided with a continuous metallic screen composed of helically applied plain annealed copper wire which shall be rated to carry the phase to earth short circuit fault current specified in Section 17.1 of this specification.</p>

3. Bidders are hereby informed that Drawing CEB-GIS-19-15a in Volume 4 has been amended by adding the position of the two existing 22/0.415 kV auxiliary transformers. The amended drawing has been renamed CEB-GIS-19-15a Rev 1.

4. Bidders are hereby informed that Drawing CEB-GIS-19-18 in Volume 4 has been amended by correcting the values of percentage impedances of existing transformers T1 and T2 to 15.0% and 15.2%, respectively and that of the new transformer, T3, to 15.0%. The amended drawing has been renamed CEB-GIS-19-18 Rev 1. Please refer to the amended drawing.
5. Bidders are hereby informed that Drawing CEB-GIS-20-13 in Volume 4 has been amended by correcting the specification of CT1 (Tank Earth CT) to 5P10, 10 VA. The amended drawing has been renamed CEB-GIS-20-13 Rev 1. Please refer to the amended drawing.

Yours faithfully,

A handwritten signature in black ink, appearing to be 'J. Lam', with a stylized, cursive script.

J. Lam
Ag. Head of Department – Supply Chain