



CENTRAL ELECTRICITY BOARD

Minutes of Meeting

PRE-BID MEETING

Open International Bidding: CPB/56/2019

Design, Supply, Construction, Testing and Commissioning of Labyrinth Type Fuse Gates at Sans Souci Dam (Mauritius)

Date and Time of Meeting : Thursday 16 January 2020 at 10h30

Venue : Sans Souci Dam

Were present:

CEB	
Mr M.K. Jahajeeah	O.I.C Production Department
Mr R. Maran	Ag. Principal Engineer (Projects)
Mr R. Dhununjoy	Senior Engineer (Generation Planning)
Mr B. Tow Nam	Ag. Senior Engineer (Hydro)
Mr V. Gaya	Civil Engineer

The list of bidders attending the pre-bid meeting is detailed below:

- Representative from Sogea Satom (Vinci)
- Representative from Hydroplus (France)
- Representatives from Transinvest Construction Ltd
- Representatives from Pad & Co ltd

1. Mr Jahajeeah welcomed all bidders present for this Pre Bid Meeting in connection with the above-mentioned project.

He highlighted that bidders should fill in the attendance sheet and that any clarifications shall be sought by writing in the Clarification Sheet provided. CEB will thereafter respond to the clarifications.

2. Mr R. Dhununjoy thereafter gave a brief overview of the project background and elaborated on the scope of works for this particular project. He also drew the attention of bidders on some salient points regarding qualification and evaluation criteria, Bid Security and time of completion.

A summary of issues raised during the pre-bid meeting and CEB's replies for each item is presented in the table below.

Item	Queries from Bidders	CEB's Replies
1	Extension of Time	
	An extension of 4 weeks was requested to the Bid Closing Date	CEB requested bidder to send a formal request for extension.
2.	Dam Level	
	An inquiry was made about the dam level during the erection of the fuse gate.	CEB informed that dam level shall be maintained at a height of 238m or lower during project implementation phase.

End of Meeting

The pre-bid meeting ended at 12:00 hrs.