



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

Central Electricity Board

CORPORATE OFFICE

P.O. BOX 134 | Rue du Savoir | Cyber City, Ebène 72201

MAURITIUS

TEL No. : (230) 404 2000
TELEFAX No. : (230) 454 7630 / 7632
E-MAIL : ceb@intnet.mu
WEBSITE : ceb.mu
VAT Reg. No. : VAT22000591
BRN : F07000041

OUR REF:

YOUR REF: **RFP-SBPU-21-056- Add 4**

22 September 2021

Attention: All Bidders

Dear Sir,

RFI-SBPU-21-056 - Purchase of Electrical Energy from Wind Farms Projects
Addendum No.4

Please refer to the above mentioned bidding exercise and take note of Addendum No 4 which shall be considered as forming part of the bidding document.

Part 1 – RFP Document

We refer to Page 13, Section 3.9 (Cyclone Resistant Wind Turbine Design) of the RFP Document. The second paragraph has been deleted and replaced as per below:

"The WTG and all associated assembly shall be designed to withstand a 3 second wind gusts of 70 m/s (250 km/hr). The Bidder has to submit test certificates whereby the wind turbine has been successfully tested in wind tunnels at the above wind speed. Alternatively, bidders will have to submit wind load calculations thereby demonstrating that the entire wind turbine assembly can withstand the above-mentioned wind gusts without any problem.

It is further brought to the attention of bidders that they have to bear any cyclonic risks associated with the wind farm project. They shall design the wind farm to resist for all extreme climatic weather conditions.

Yours faithfully,

R. Chowdharry
Supply Chain Manager